

Certificate No: **TAA00009C** 

# TYPE APPROVAL CERTIFICATE

_			-		
Τh	16	16	to	certify:	
	13	13	LU	CCI LIIV.	

That the Pressure Transmitter

with type designation(s) 27A, 27I, 27D, 27M

Issued to

VALCOM S.R.L. TERRANOVA P., LO, Italy

is found to comply with

DNV GL rules for classification - Ships and offshore units

### **Application:**

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

#### **Location classes:**

Туре	Temperature	Humidity	Vibration	EMC	Enclosure
27A	С	В	В	Α	C*
<b>27I</b>	С	В	В	Α	D
27D	С	В	В	Α	C*
27M	С	В	В	Α	C*

<sup>\*</sup> When plug connection is selected the enclosure class is B

This Certificate is valid until 2019-06-30.

Issued at Høvik on 2016-02-17

for DNV GL

DNV GL local station: Milan

Approval Engineer: Ståle Sneen

Odd Magne Nesvåg

Head of Section

Form code: TA 1411a Revision: 2015-05 www.dnvgl.com Page 1 of 2

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

Job Id: **262.1-003626-4** Certificate No: **TAA000009C** 

# **Product description**

Pressure/Level Transmitter 27A Submersible Level Transmitter 27I Differential Pressure Transmitter 27D P/I Converter 27M

### **Application/Limitation**

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Ex-certification is not covered by this certificate. Application in hazardous area to be approved in each case according to the Rules and Ex-Certification/ Special Condition for Safe Use listed in valid Excertificate issued by a notified/recognized Certification Body.

# Type Approval documentation Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, November 2015.

# **Marking of product**

Manufacturer: VALCOM S.R.L

Model name: As listed under Product description Serial number: Unique for each delievered item

#### Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed at least every second year and at renewal of this certificate.

**END OF CERTIFICATE** 

Form code: TA 1411a Revision: 2015-05 www.dnvgl.com Page 2 of 2